



Product Service

CERTIFICATE

No. B 078705 0029 Rev. 00

Holder of Certificate: CITEL SAS

2 Rue Troyon
92316 Sèvres CEDEX
FRANCE

Certification Mark:



Product:

**Surge protection equipment
AC surge protector**

Model(s):

**DACN1-13S-10-760, DACN1-13S-20-760
DACN1-13S-30-760, DACN1-13S-40-760**

Parameters:

Max. continues operating voltage U_C :	760 V AC
Voltage protection level (U_P):	3,5 kV
Norminal discharge current I_n (8/20 μ s):	40 kA
Maximum discharge current I_{max} (8/20 μ s):	80 kA
Impulse discharge current I_{imp} (10/350 μ s):	12,5 kA
Test class:	T1+T2
Degree of protection:	IP20
Temperature range:	Extended

Tested according to: EN 61643-11:2012/A11:2018

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 874102430701-00

Valid until: 2029-06-26

Date, 2024-06-27

(Hongbo Zhu)